



**GENERATORS**

First Generator S/N # \_\_\_\_\_ (etched on the side)

 Replace 15 years from *date* (year/month) \_\_\_\_\_

Second Generator S/N # \_\_\_\_\_ (etched on the side)

 Replace 15 years from *date* (year/month) \_\_\_\_\_

 (See *date* punched out on Stat-X label attached to generator)

Are the generator mounting brackets secured with 2 bolts each? Y N N/A

Are the generators mounted with the discharge end (flat end)

toward the heat source? Y N N/A

Are the protective disks present on the discharge ends of

both generators? Y N N/A

Are the generator decals damage free and legible? Y N N/A

**LED**

Is the green LED on the dash illuminated? Y N N/A

Is the green LED clearly visible from the driver's seat? Y N N/A

 Is the *Automatic Fire Suppression* and CAUTOIN stickers

damage free and visible to the driver? Y N N/A

**MANUAL ACTIVATION SWITCH**

Is the Manual Activation Switch securely fastened in place? Y N N/A

Is the pin and seal in place with the switch in the off position? Y N N/A

 Is the *Manual Activation Switch* stickers damage free and

visible to the driver? Y N N/A

